



Radioactivity in residues and effluents from Estonian waterworks treatment plants

*Cristina Nuccetelli**, *E. Caldognetto+*,
M. Forte°, *F. Realini§*, *S. Risica**, *R. Rusconi°*, *F. Trotti†*

*Istituto Superiore di Sanità (Italian National Institute of Health), Rome, ITALY

+ARPAV (Environmental Protection Agency of Veneto), Verona, ITALY

°ARPA Lombardia (Environmental Protection Agency of Lombardia), Milano, ITALY

§Consorzio CO.META, Milano, ITALY

European Commission: Estonian Transition Facility

Twinning Project between Estonia and Italy: “Estimation of concentrations of radionuclides in Estonia drink waters and related health risks” January – September 2009

Environmental Protection Agency of Lombardia (ARPA Lombardia)

Environmental Protection Agency of Veneto (ARPA Veneto)

National Institute of Health (ISS)

Consultants – Aqueduct Management & Water Treatment Plants

Health Protection Inspectorate (Terviseamet)

Geological Survey of Estonia (EGK)

Radiation Protection Center (Kiirguskeskus)

University of Tartu

Tallinn Technical University

Estonian Water Producer Association & Waterworks Societies



THE PROBLEM:

- Some groundwaters in Northern Estonia exhibit rather high natural radioactivity, mainly due to ^{226}Ra and ^{228}Ra .
- EC Directive 98/83/EC: Total Indicative Dose 0.1 mSv/year (parametric value)
- Enforced in Estonia national regulation in 2001 (dose limit)



THE TASK:

REVIEWING THE EXISTING KNOWLEDGE

Radiological (and chemical) database

Analytical methods

Waterworks and water distribution structure

Water treatment plants



SUGGESTION ON

Future monitoring campaigns

Dosimetric evaluations

Fit for purpose analytical methods/strategy

Countermeasures


Radioactivity removal and sludge managing

Estimation of concentrations of radionuclides in Estonian groundwaters and related health risks – Final Report

High radium concentrations are found mostly in the deepest aquifer (Cambrian-Vendian): it lays on a crystalline rock basement. It is hardly recharged and the water is very old.


The Cambrian-Vendian aquifer is shallower (about 100 m) near the Baltic sea coastline. In this area it is used to feed waterworks.

The coastal area is the most densely populated




Total Indicative Dose (TID)

TID adults





Cm-V

TID infants




others




Average relative contributions of the two Ra isotopes to dose.

adults




infants



M Forte et al. *Radium isotopes in Estonian groundwater: measurements, analytical correlations, population dose and a proposal for a monitoring strategy*
Journal of Radiological Protection, 30(4), 761-780

Dimensions of Water Supply Zones (Cm-V)

Total: 140 WSZ; 250.000 people



**Wastes and sludges:
Dosimetric evaluation
Enviromental impact**

Effluents and residues from existing treatment plants

- 4 Estonian aqueducts with waters rich in ^{226}Ra and ^{228}Ra and treatment systems surveyed in the year 2009.
- data collected for a preliminary evaluation of the potential impact on the environment of the effluents and residues formed during the treatment processes.
- radium activity concentrations in water and residues were assessed by several laboratories, among them the Estonian Radiation Protection Centre, the Tartu University and the STUK (Finland).

Effluents and residues from existing treatment plants (cont.I)

- *Tallinn waterworks*

- **85 wells** afferent to 56 pumping stations, 19 supplied with treatment systems.
- **water** filtered through sand and gravel to remove Fe, Mn and NH_4 ; an aeration stage precedes the filtering.
- **filters** periodically cleaned by backwash water then channelled to sewage.
- **all backwash** conveyed to a single sewer (that of Tallinn city) waters (about 400,000 inhabitants).
- **sludge** used as filling material in landscape construction projects
- **purified water** released into the sea.

Information on effluents from waterworks treatment plants of Tallinn

Treatment Station	Treatment type	Backwash water (m ³ /y)	Backwash water		Fate	Backwash water	
			²²⁶ Ra (Bq/m ³)	²²⁸ Ra (Bq/m ³)		²²⁶ Ra (Bq/y)	²²⁸ Ra (Bq/y)
Jugapuu		1708	3100	8700		5.29E+06	1.49E+07
Raba	Stations with sand/ gravel filters for Fe, Mn, NH ₄ removal (pre-aerated)	507	8730	14710	Sewer	4.43E+06	7.46E+06
Toome - Õitse		1018	9350	13650		9.52E+06	1.39E+07
Tiskre		581	5320	6040		3.09E+06	3.51E+06
All other Stations		17428	n.a. [°]	n.a. [°]	Sewer		
TOTAL		21242	6625*	10775*		1.41E+08	2.29E+08

* Average concentration value; ° not available

Effluents and residues from existing treatment plants (cont.III)

- *Viimsi waterworks*
 - water drawn from 35 independent wells
 - pilot treatment device for radium purification operating at well # 412
 - ✓ two parallel filtration columns + additional common cleaning stage.
 - backwash water conveyed to the same sewer used by the Tallinn waterworks.

Information on effluents from treatment plants of Keila, Rakvere and Viimsi

Water works	Treatment Station	Treatment type	Backwash water (m ³ /y)	Backwash water		Fate	Backwash water	
				²²⁶ Ra (Bq/m ³)	²²⁸ Ra (Bq/m ³)		²²⁶ Ra (Bq/y)	²²⁸ Ra (Bq/y)
Keila	All 4 wells	Sand filters for Fe and Mn removal (preaerated)	1400	1380	1580		1.93E+06	2.21E+06
Rakvere	All 5 wells	Sand filters for Fe removal (aerated)	36500	1774	1796	Sewer	6.48E+07	6.56E+07
Viimsi	Well # 412	column I + column II (in parallel) for Ra purification	9.0	1805	2050		1.62E+04	1.85E+04

In conclusion $^{228}\text{Ra} \geq ^{226}\text{Ra}$

REFERENCE DOCUMENTS FOR CLEARANCE LEVELS AND EFFLUENT DISCHARGE SCREENING LEVELS

- Waterworks treatment processes may be regarded as work activities involving NORM
- the EC BSS draft includes them in the positive list of NORM activities
- Estonian national legislation does not define reference values for NORM wastes or discharges; evaluate the adequacy of processes, reference should be made to available international or national technical guides

Solid residues

- In the analysed waterworks solid residues are mainly sand filters.
- The document Radiation Protection 122 (RP 122) - part II derives General Clearance Levels (GCLs) for natural radionuclides in residues and waste from work activities involving NORM
- it is useful to classify waterworks solid residues

General Clearance Levels (GCLs) from RP 122 - part II

	$^{226}\text{Ra}^*$ (Bq/kg)	$^{228}\text{Ra}^*$ (Bq/kg)	$^{228}\text{Th}^*$ (Bq/kg)
All materials	500	1000	500

* In secular equilibrium with short half-life decay products

residues with activity concentrations < GCLs can be reused, recycled, delivered for disposal with no constraint as for their radiological aspects

GCLs determined to comply with the exemption-clearance dose criterion of 0.3 mSv/y for the individual effective dose.

Information on residues from waterworks treatment plants

Waterworks	Treatment station	Material	²²⁶ Ra (Bq/kg)	²²⁸ Ra (Bq/kg)	²²⁸ Th (Bq/kg)
<i>Tallinn</i>	<i>Merivälja</i>	Sand	8603	8681	5798
<i>Keila</i>	<i>All 4 wells</i>	Sand filter 1	5524	5754	3817
		Sand filter 2	5202	5618	3139
<i>Rakvere</i>	<i>All 5 wells</i>	Sand filter	3788	3047	1768
		Backwash water sediment	20103	15034	7176

All values > or >> GCL

Comparison between solid residues from existing treatment plants and GCLs of RP 122

Waterworks	Treatment station	Material type	Sum index*
<i>Tallinn</i>	Merivalja	Sand	37
<i>Keila</i>	All 4 wells	Sand filter (sample 1)	24
		Sand filter (sample 2)	22
<i>Rakvere</i>	All 5 wells	Sand filter	14
		Backwash water sediment	70

* The sum index is the sum of ratios of single nuclide activity to the respective GCLs; for compliance it should be less than 1.

No material complies with RP 122 levels

Comparison between solid residues from existing treatment plants and GCLs of RP 122 (cont.)

- GCLs selected from the most conservative conditions (material type, reference scenario and population group), i.e. people living in a house whose building materials contain the radioactive residues
- unrealistic scenario for solid residues from drinking water treatment plants

BUT

- also in a different, more realistic scenario (e.g. exposure of workers that use contaminated material for road construction or people living in houses close to a disposal site of contaminated residues), compliance not achieved
- no solid material complies with the reference levels, not even when compared with the clearance levels of the EC BSS draft (1000 Bq/kg individually applied to ^{226}Ra , ^{228}Ra and ^{228}Th , with or without short half-life progeny in secular equilibrium).

REFERENCE DOCUMENTS FOR EFFLUENT DISCHARGE SCREENING LEVELS

The assessment of the radiological impact of effluent discharges based on three documents giving discharge screening levels from very conservative scenarios.

- 1) the IAEA Safety Rep. “Generic models for use in assessing the impact of discharges ...”
 - reference levels for liquid discharge into small rivers and sewers
 - critical scenario: workers exposure in the sewing plant for discharge into sewer
- 2) the EC RP 135 “Effluent and dose control from European Union NORM industries:...”
 - screening levels concerning release into rivers of various sizes and into coastal sea.
- 3) the document NRPB 13 n.2 “Generalised Derived Constraints for....Po, Pb, Ra and U”
 - reference levels for liquid discharge into small rivers and sewers
 - critical scenario: use of sludge on farmland for discharge into sewer

REFERENCE DOCUMENTS FOR EFFLUENT DISCHARGE SCREENING LEVELS (cont.)

RP 135 and NRPB 13: screening levels calculated with a dose criterion of 0.3 mSv/y (individual effective dose)

EC BSS draft also considers 0.3 mSv/y the dose for public exposure to NORM work activities as a general clearance criterion.

IAEA: individual annual dose for unit discharge of main radionuclides; screening levels calculated depending on dose criterion

IAEA and EC documents suggest reference values at the international level
NRPB document only sets national standards.

CHOICE OF SCREENING LEVELS FOR EFFLUENTS

Tallinn (+ Viimsi) and Keila plants:

- waters from filter cleaning to the sewer
- sludge formed in the process not used in agriculture.
 - IAEA values for sewer and screening levels on the basis of the 0.3 mSv/y (levels scaled to account for the 400 000 inhabitants of Tallinn vs. 20 000 modelled; proportional dilution of the radioactivity)
- purified waters from the sewer released into the sea
 - an alternative conservative assumption: sewer sludge contains no radium from backwash water, all radium is discharged into the sea - comparison with RP 135 screening levels for coastal sea

Rakvere:

- backwash waters flow to the sewage system
- resulting sludge used in farmland treatment:
 - NRPB General Derived Constraint in sewer; agricultural scenario the most critical one in case of discharge into the sewer. Test only carried out for ^{226}Ra , the ^{228}Ra GDC not available
- purified waters from the sewer released into a small river:
 - an alternative conservative assumption: all radium content of backwash water discharged into the river; comparison with RP 135 screening levels for discharge into a river

Discharge screening levels for backwash water

Compartment	Critical pathway	^{226}Ra (Bq/y)	^{228}Ra (Bq/y)	Reference
Sewer	Sewer workers	$3.8 \cdot 10^9$	$2.7 \cdot 10^9$	IAEA 19 (Tallinn)*
Sewer	Sludge for agriculture	$1 \cdot 10^7$	n.a.	NRPB 13 n.2
Coastal sea	Ingestion (fish)	$2.2 \cdot 10^{13}$	$1.2 \cdot 10^{13}$	RP 135
Small river	Ingestion (fish)	$7.5 \cdot 10^{10}$	$4.2 \cdot 10^{10}$	RP 135

* Screening levels scaled to account for the number of inhabitants served by the Tallinn sewer

Discharge screening levels applied to backwash waters of existing treatment plants

Waterworks	Compartment	Sum index*	Reference
Tallinn and Viimsi [°]	Sewer	1.22E-01	IAEA 19
Tallinn and Viimsi [°]	Coastal sea	2,55E-05	RP 135
Keila	Sewer	2.60E-02	IAEA 19
Rakvere	Sewer	<u>6.48</u>	NRPB 13 n. 2
Rakvere	River (small)	2.42E-03	RP 135

* The sum index is the sum of ratios of single nuclide activity to the respective GCLs; for compliance it should be less than 1.

[°]As backwash waters from Tallinn and Viimsi treatment plants flow into the same sewer (Tallinn city), their contributions were added for the comparison.

Conclusions 1

Solid residues (sand filters and backwash water sediments):

- ^{226}Ra , ^{228}Ra and ^{228}Th activity concentrations higher than both the general clearance levels suggested by RP122 part II and the exemption and clearance levels set by the EU BSS draft
- compliance could be demonstrated case by case with dose calculations in specific scenarios, taking into account the actual use and radiological impact of the residues.

Liquid effluents:

- all but those from the Rakvere treatment plant (sewer compartment) comply with IAEA and EC discharge screening levels
- Rakvere sewer compartment produces sewer sludge used on farmland and the relevant NRPB assumptions for calculating screening levels are highly conservative

Conclusions 2

Suggestions :

- need for a more robust assessment:
- more realistic scenarios
- all radionuclides in backwash water accounted for
- special care must be taken when managing solid residues
- more detailed surveys and systematic analyses of radiation protection aspects should be made as soon as the new EC BSS will be transposed in the Estonian legislation.

Thank you for your attention

