EU-NORM2 2014, Prague, Czech Republic

Aerosols Containing Natural Radionuclides in Coal-Fired Power Plant



k360cwc@kins.re.kr







Background and Study Objectives

Introduction

- Coal-fired power plant is a typical way to generate electricity:
 - About 45% of gross generation in Korea (1st)
- Coal-fired power plant generates residues in progress of coal combustion:
 - Fly ash, Bottom ash
 - FGD (Flue-gas desulfurization) gypsum

Residues contain natural radionuclides:

- U-238, U-235 and Th-232 series
- Low activities concentration
- However, it may cause not-trivial radiation dose to workers due to mainly inhalation of airborne particles

Management of natural radionuclides in Korea


 Enforced "Act on Safety Control of Radioactive Rays around Living Environment" (2012) by a government agency, NSSC (Nuclear Safety and Security Commission)

SSC has worked to protect the public from NORM.

- Current status of NORM in the country (raw materials, residues, the products, etc.)
- Production process of the industry and flow of the NORM in the process
- Working environment of the workers
- Characterization of the NORM (radioactivity concentration, airborne particle properties, others for radiation protection)
- Radiation dose assessment

ICRP 66 Human Respiratory Tract Model (HRTM)

✓ Radiation dose due to particle inhalation can be estimated by ICRP 66 HRTM.



Respiratory tract morphometry

Deposition & clearance compartment model

ICRP 66 Human Respiratory Tract Model

✓ HRTM for radiological protection


✓ Contents

- Morphometry
- Respiratory physiology
- Radiation biology
- Deposition model
- Clearance model
- Dosimetry model

✓ Advantages

- Ability to explicitly consider particle properties
- (eg) particle size distribution, shape, density, etc.

Parameters Influencing Inhalation Dose




Objectives

- To characterize airborne particles containing natural radionuclides in the coal-fired power plants
 - To study sensitivity of inhalation dose to particle properties
 - To establish a database of particle properties, including particle size distribution, shape, and density.
 - To establish a database of radionuclide concentrations in the NORM.
 - The database will be used for site-specific assessment of radiation doses to workers.

Dose Sensitivity to Particle Properties

Particle Properties Influencing Dose

- Airborne particle properties necessary for internal dosimetry
 - Particle size distribution
 - Particle density
 - Particle shape
 - Radioactivity concentration
 - Solubility in the lung




Input Parameters for Dose Sensitivity Study


Aerosol Parameters	ICRP 66 Reference Values	Input Parameters
AMAD	5 μm (workplace) 1 μm (general public)	0.01 – 100 μm
GSD	2.5 (5 μm AMAD) 2.47 (1 μm AMAD)	1 and GSD _{ICRP66} ²
Density	3 g/cm	0.7 and 11 g cm ⁻³
Shape factor	1.5	1 and 2
Absorption type	type M (²³⁸ U) type S (²³⁰ Th)	type M (²³⁸ U) type S (²³⁰ Th)

Dose Sensitivity to Particle Properties

✤ U-238







Properties of Airborne Particles

Airborne Particle Concentration and Size Distribution

Sampling Facilities & Concerning Areas

2 coal-fired power plants

Plant	Sampling Location	
Coal-fired plant A	Coal yard (exterior) Fly-ash silo	
Coal-fired plant B	Unloading dock of anthracite coal Coal yard (interior) Fly-ash silo	



Coal yard (exterior)

Unloading dock

Coal yard (interior)

Fly-ash silo


Air Sampling

8-stage cascade impactors



High Capacity Pre-Seperator






Stage	Range of Collected Aerosols (µm)	Geometric mean of Aerosols (µm)
0	9.00-100	30.00
1	5.80-9.00	7.22
2	4.70-5.80	5.22
3	3.30-4.70	3.94
4	2.10-3.30	2.63
5	1.10-2.10	1.52
6	0.65-1.10	0.88
7	0.43-0.65	0.53
filter	0.03-0.43	0.11



Particle Size Distribution

- ✤ Range : 0.03-100 µm
- ✤ Highest concentration : 4.7-5.8 & 5.8-9.0 µm




Various with processing area

- Similar distributions were shown at same processing area from Coal-fired plant A & B.
- Different distributions at coal yard
 - Due to the difference of storage facilities
 - Exterior storage (A) and interior storage (B)

Reference Aerosol Parameters in ICRP 66

- In the absence of particle information, ICRP 66 HRTM suggests reference aerosol parameters.
- Reference aerosol parameter



✓ Size distribution

- Log-normal distribution
- GSD = 2.5 (5 μ m AMAD)
- GSD = 2.47 (1 μ m AMAD)
- ✓ Median particle size (AMAD)
 - Occupational exposure : 5 mm
 - Environmental exposure : 1 mm
- Shape factor (χ):
 1.5
- ✓ Mass density:
 3 g/cm³

Airborne Particle Shape and Density

Particle Deposition Model in ICRP 66


Filtration efficiency (η)

- Function of aerodynamic diameter (d_{ae}) and thermodynamic diameter (d_{th})

• Relation $d_{ae} \& d_{th}$

$$d_{th} = d_{ae} \sqrt{rac{\chi
ho_0}{
ho}} imes rac{C(d_{ae})}{C(d_{th})}$$

- χ : shape factor
- ρ : particle density
- C: slip correction factor



Shape and Density Analysis


- 12 samples of raw-materials and residues
- ✤ Analysis
 - SEM
 - Pycnometer





Shapes of Airborne Particles

◆ Spherical particles were shown at all stages
 → Particle shape factor (χ) : 1



(A) 0 stage(B) 3 stage(C) 5 stage(D) 7 stage

Mass Density of Particles

Plant	Location	Sample	Density (g/cm³)
Plant A	Coal yard (exterior)	Bituminous coal (Australia) Bituminous coal (Canada) Bituminous coal (Indonesia) Bituminous coal (Russia) Bituminous coal (U.S.A.)	$\begin{array}{l} 1.4 \ \pm \ 0.01 \\ 1.4 \ \pm \ 0.01 \\ 1.4 \ \pm \ 0.02 \\ 1.4 \ \pm \ 0.03 \\ 1.5 \ \pm \ 0.01 \end{array}$
	Fly-ash silo	Fly ash	2.4 ± 0.01
	Bottom-ash landfill	Bottom ash	1.5 ± 0.04
	FDG gypsum storage	FDG gypsum	2.4 ± 0.02
Plant B	Unloading dock of bituminous coal	Bituminous coal (Russia)	1.5 ± 0.05
	Unloading dock of anthracite coal	Anthracite coal (Domestic)	2.1 ± 0.03
	Fly-ash silo	Fly ash	2.5 ± 0.03
	Bottom-ash landfill	Bottom ash	2.9 ± 0.05

Coal

- Bituminous coal : 1.4 1.5 g/cm3
- Anthracite coal : 2.1 g/cm3

Ash

- Fly ash : 2.4 2.5 g/cm3
- Bottom ash
 - . 1.5 g/cm³ (Plant A) ~ 2.9 g/cm³ (Plant B)
 - . Plant A : Use of only bituminous coal
 - Plant B : Use of bituminous coal and anthracite coal

FDG (flue-gas desulfurization) gypsum

- 2.4 cm3

Radionuclide Concentrations

Radioactivity Measurement

✤ HPGe



Radionuclide Concentration

Ra-226, 228 : under 1 Bq/g

→ Exemption level

Plant A

Location	Sample	Activity Concentration (Bq/kg)		
		Ra-226	Ra-228	K-40
Coal yard (exterior)	Coal (Australia)	18 ± 5	16 ± 3	77 ± 5
	Coal (Canada)	8 ± 2	5 ± 1	23 ± 3
	Coal (Indonesia)	7 ± 1	13 ± 2	33 ± 3
	Coal (Russia)	20 ± 3	14 ± 2	66 ± 4
	Coal (USA)	18 ± 3	12 ± 2	88 ± 5
Fly-ash silo	Fly ash	151 ± 14	123 ± 10	325 ± 17
Bottom-ash Iandfill	Bottom ash	103 ± 10	94 ± 9	455 ± 23
FDG gypsum storage	FDG gypsum	6 ± 1	2 ± 1	27 ± 2



Location	Sample	Activity Concentration (Bq/kg)		
		Ra-226	Ra-228	K-40
Unloading dock of bituminous coal	Coal(Russia)	22 ± 3	24 ± 3	59 ± 4
Unloading dock of anthracite coal	Coal(Domestic)	59 ± 6	75 ± 7	489 ± 24
Fly-ash silo	Fly ash	87 ± 9	99 ± 8	388 ± 20
Bottom-ash Iandfill	Bottom ash	83 ± 8	100 ± 9	536 ± 26

Summary

Summary

Radiation dose due to particle inhalation greatly depends on particle properties

- Dose assessment without such information may distort radiation dose to unrealistic value.
- A database of airborne particle properties were established at 2 coal-fired power plants

- The properties including airborne particle concentration and size distribution, shape, mass density, and radionuclide concentrations

The findings can be used as a basic data for development of safety standard and guide and for practical radiation safety management. Always we keep watching our Radiation Safety

Thank You

